

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET
WASHINGTON, NEW JERSEY 07882
NJDEP CERT# 21016
908-835-2510

Date of Report: 4/28/21
Project Name: 71 Route 46
Sample Date & Time: 4/26/21 10:45AM
Sampled by: JB

71 Route 46, Knowlton Twp
Collection Point: Men's Bathroom Tap
Treatment in Place: UV Light
(treated sample)

Parameter	Result	MCL	Procedure	NJ Lab Cert #	Analysis Date/Time
Total Coliform	Absent	0 (Absent)	Std. Method 9223-B	03036	4/27/21 11:05AM
E. coli	Absent	0 (Absent)	Std. Method 9223-B	03036	4/27/21 11:05AM

The results reported for the above referenced property meet the New Jersey Drinking Water Standards.

I certify that these test results are technically complete, and all procedures follow the analytical methods identified.



Harold Blaine
Laboratory Manager

MCL - Maximum Contaminant Level
