

ALL-STATE WELL TESTING SERVICES, LLC

11-13 BROAD STREET
WASHINGTON, NEW JERSEY 07882
NJDEP CERT# 21016
908-835-2510

Date of Report: 12/30/21
Project Name: 71 Route 46 (Mobil)
Sample Date & Time: 12/28/21 9:28AM
Sampled By: JH

71 Route 46, Columbia
Collection Point: Men's Restroom
Treatment in place: UV Light
(Treated Water)

Parameter	Result	MCL	Procedure	NJ Lab Cert #	Analysis Date/Time
Total Coliform	Absent	Absent	Std. Method 9223-B	03036	12/29/21 09:30
E. Coli	Absent	Absent	Std. Method 9223-B	03036	12/29/21 09:30

The results reported for the above property HAVE met New Jersey Drinking Water Standards.

I certify that these test results are technically complete, and all procedures follow the analytical methods identified.



Harold Blaine
Laboratory Manager

MCL – Maximum Contaminant Level

Bold Result - At the time of sampling this parameter does not meet NJDEP Standards for drinking water.
